

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

NOx			
Daily ELV	100	mg/Nm ³	STA reportable 696
Half-hourly ELV	100	mg/Nm ³	STA invalidated 2
ELV P	400	mg/Nm ³	STA periods 1488
ELV S	400	mg/Nm ³	

Day	Status	Daily VLTA mg/Nm ³	Daily VLTA > ELV	VSTA > ELV	SSTA > calibr. range %	FLD outside meas. range	Subst. values in SSTA
01.01.21	Invalid	-	-	0	0.00	0	0
02.01.21	Invalid	-	-	0	0.00	0	0
03.01.21	Invalid	-	-	0	0.00	0	0
04.01.21	Invalid	-	-	0	0.00	0	0
05.01.21	Invalid	-	-	0	0.00	0	0
06.01.21	Invalid	-	-	0	0.00	0	0
07.01.21	Invalid	-	-	0	0.00	0	0
08.01.21	Invalid	-	-	0	0.00	0	0
09.01.21	Invalid	-	-	0	0.00	0	0
10.01.21	Invalid	-	-	0	0.00	0	0
11.01.21	Invalid	-	-	0	0.00	0	0
12.01.21	Invalid / P	-	-	0	0.00	0	4
13.01.21	Valid / P	89.86	0	0	0.00	0	1
14.01.21	Invalid / P	-	-	0	0.00	0	1
15.01.21	Valid / P	143.63 !	1	0	0.00	0	0
16.01.21	Valid / P	93.86	0	15	0.00	0	0
17.01.21	Valid / P	97.00	0	3	0.00	0	0
18.01.21	Valid / P	188.40 !	1	1	0.00	0	2
19.01.21	Valid / P	70.12	0	0	0.00	0	0
20.01.21	Valid / P	66.06	0	0	0.00	0	3
21.01.21	Valid / P	45.04	0	0	8.33	0	0
22.01.21	Valid / P	66.75	0	0	0.00	0	1
23.01.21	Invalid	-	-	0	0.00	0	0
24.01.21	Valid / P	79.18	0	0	0.00	0	2
25.01.21	Valid / P	77.81	0	0	0.00	0	1
26.01.21	Invalid / P	-	-	0	0.00	0	0
27.01.21	Valid / P	93.67	0	0	0.00	0	3
28.01.21	Valid / P	69.58	0	0	0.00	0	0
29.01.21	Valid / P	68.99	0	0	0.00	0	0
30.01.21	Valid / P	63.56	0	0	0.00	0	0
31.01.21	Valid / P	66.60	0	0	0.00	0	0
Average / Sum	Valid	86.18	2	19	0.27	0	18
Minimum		45.04			0.00		
Maximum		188.40			8.33		
Cumulative [%]			12.50	2.73			

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

SO2							
Daily ELV	50	mg/Nm ³			STA reportable	696	
Half-hourly ELV	200	mg/Nm ³			STA invalidated	2	
ELV P	200	mg/Nm ³			STA periods	1488	
ELV S	200	mg/Nm ³					
Day	Status	Daily VLTA mg/Nm ³	Daily VLTA > ELV	VSTA > ELV	SSTA > calibr. range %	FLD outside meas. range	Subst. values in SSTA
01.01.21	Invalid	-	-	0	0.00	0	0
02.01.21	Invalid	-	-	0	0.00	0	0
03.01.21	Invalid	-	-	0	0.00	0	0
04.01.21	Invalid	-	-	0	0.00	0	0
05.01.21	Invalid	-	-	0	0.00	0	0
06.01.21	Invalid	-	-	0	0.00	0	0
07.01.21	Invalid	-	-	0	0.00	0	0
08.01.21	Invalid	-	-	0	0.00	0	0
09.01.21	Invalid	-	-	0	0.00	0	0
10.01.21	Invalid	-	-	0	0.00	0	0
11.01.21	Invalid	-	-	0	0.00	0	0
12.01.21	Invalid / P	-	-	0	0.00	0	4
13.01.21	Valid / P	3.30	0	0	0.00	0	1
14.01.21	Invalid / P	-	-	0	0.00	0	1
15.01.21	Valid / P	3.00	0	0	0.00	0	0
16.01.21	Valid / P	0.00	0	0	0.00	0	0
17.01.21	Valid / P	0.23	0	0	0.00	0	0
18.01.21	Valid / P	0.33	0	0	0.00	0	2
19.01.21	Valid / P	0.11	0	0	0.00	0	0
20.01.21	Valid / P	30.73	0	1	0.00	0	3
21.01.21	Valid / P	0.00	0	0	8.33	0	0
22.01.21	Valid / P	0.04	0	0	0.00	0	1
23.01.21	Invalid	-	-	0	0.00	0	0
24.01.21	Valid / P	5.63	0	0	0.00	0	2
25.01.21	Valid / P	0.00	0	0	0.00	0	1
26.01.21	Invalid / P	-	-	0	0.00	0	0
27.01.21	Valid / P	0.01	0	0	0.00	0	3
28.01.21	Valid / P	0.00	0	0	0.00	0	0
29.01.21	Valid / P	0.00	0	0	0.00	0	0
30.01.21	Valid / P	0.01	0	0	0.00	0	0
31.01.21	Valid / P	0.01	0	0	0.00	0	0
Average / Sum	Valid	0.00	0	1	0.27	0	18
Minimum		0.00			0.00		
Maximum		30.73			8.33		
Cumulative [%]			0.00	0.14			

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

Dust							
Daily ELV	10	mg/Nm ³			STA reportable	696	
Half-hourly ELV	30	mg/Nm ³			STA invalidated	1	
ELV P	150	mg/Nm ³			STA periods	1488	
ELV S	150	mg/Nm ³					
Day	Status	Daily VLTA mg/Nm ³	Daily VLTA > ELV	VSTA > ELV	SSTA > calibr. range %	FLD outside meas. range	Subst. values in SSTA
01.01.21	Invalid	-	-	0	0.00	0	0
02.01.21	Invalid	-	-	0	0.00	0	0
03.01.21	Invalid	-	-	0	0.00	0	0
04.01.21	Invalid	-	-	0	0.00	0	0
05.01.21	Invalid	-	-	0	0.00	0	0
06.01.21	Invalid	-	-	0	0.00	0	0
07.01.21	Invalid	-	-	0	0.00	0	0
08.01.21	Invalid	-	-	0	0.00	0	0
09.01.21	Invalid	-	-	0	0.00	0	0
10.01.21	Invalid	-	-	0	0.00	0	0
11.01.21	Invalid	-	-	0	0.00	0	0
12.01.21	Invalid / P	-	-	0	0.00	0	4
13.01.21	Valid / P	0.44	0	0	0.00	0	1
14.01.21	Invalid / P	-	-	0	0.00	0	1
15.01.21	Valid / P	0.54	0	0	0.00	0	0
16.01.21	Valid / P	0.56	0	0	0.00	0	0
17.01.21	Valid / P	0.62	0	0	0.00	0	0
18.01.21	Valid / P	1.06	0	0	0.00	0	2
19.01.21	Valid / P	0.44	0	0	0.00	0	0
20.01.21	Valid / P	1.88	0	0	0.00	0	3
21.01.21	Valid / P	0.00	0	0	8.33	0	0
22.01.21	Valid / P	0.32	0	0	0.00	0	1
23.01.21	Invalid	-	-	0	0.00	0	0
24.01.21	Valid / P	0.54	0	0	0.00	0	2
25.01.21	Valid / P	0.39	0	0	0.00	0	1
26.01.21	Invalid / P	-	-	0	0.00	0	0
27.01.21	Valid / P	0.37	0	0	0.00	0	3
28.01.21	Valid / P	0.32	0	0	0.00	0	0
29.01.21	Valid / P	0.33	0	0	0.00	0	0
30.01.21	Valid / P	0.34	0	0	0.00	0	0
31.01.21	Valid / P	0.33	0	0	0.00	0	0
Average / Sum	Valid	0.40	0	0	0.27	0	18
Minimum		0.00			0.00		
Maximum		1.88			8.33		
Cumulative [%]			0.00	0.00			

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

TOC							
Daily ELV	10	mg/Nm ³			STA reportable	696	
Half-hourly ELV	20	mg/Nm ³			STA invalidated	0	
ELV P	20	mg/Nm ³			STA periods	1488	
ELV S	20	mg/Nm ³					
Day	Status	Daily VLTA mg/Nm ³	Daily VLTA > ELV	VSTA > ELV	SSTA > calibr. range %	FLD outside meas. range	Subst. values in SSTA
01.01.21	Invalid	-	-	0	0.00	0	0
02.01.21	Invalid	-	-	0	0.00	0	0
03.01.21	Invalid	-	-	0	0.00	0	0
04.01.21	Invalid	-	-	0	0.00	0	0
05.01.21	Invalid	-	-	0	0.00	0	0
06.01.21	Invalid	-	-	0	0.00	0	0
07.01.21	Invalid	-	-	0	0.00	0	0
08.01.21	Invalid	-	-	0	0.00	0	0
09.01.21	Invalid	-	-	0	0.00	0	0
10.01.21	Invalid	-	-	0	0.00	0	0
11.01.21	Invalid	-	-	0	0.00	0	0
12.01.21	Invalid / P	-	-	0	0.00	0	4
13.01.21	Valid / P	0.16	0	0	0.00	0	1
14.01.21	Invalid / P	-	-	2	0.00	1	1
15.01.21	Valid / P	2.09	0	0	0.00	0	0
16.01.21	Valid / P	0.18	0	0	0.00	0	0
17.01.21	Valid / P	0.82	0	1	0.00	0	0
18.01.21	Valid / P	1.21	0	1	0.00	2	2
19.01.21	Valid / P	0.43	0	0	0.00	0	0
20.01.21	Valid / P	2.12	0	1	0.00	1	3
21.01.21	Valid / P	0.00	0	0	8.33	0	0
22.01.21	Valid / P	0.13	0	0	0.00	0	1
23.01.21	Invalid	-	-	0	0.00	0	0
24.01.21	Valid / P	18.85 !	1	6	0.00	1	2
25.01.21	Valid / P	1.21	0	0	0.00	0	1
26.01.21	Invalid / P	-	-	1	0.00	0	0
27.01.21	Valid / P	2.29	0	1	0.00	2	3
28.01.21	Valid / P	0.12	0	0	0.00	0	0
29.01.21	Valid / P	0.13	0	0	0.00	0	0
30.01.21	Valid / P	0.13	0	0	0.00	0	0
31.01.21	Valid / P	0.13	0	0	0.00	0	0
Average / Sum	Valid	1.15	1	13	0.27	7	18
Minimum		0.00			0.00		
Maximum		18.85			8.33		
Cumulative [%]			6.25	1.87			

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

HCI							
Daily ELV	10	mg/Nm ³			STA reportable	696	
Half-hourly ELV	60	mg/Nm ³			STA invalidated	2	
ELV P	60	mg/Nm ³			STA periods	1488	
ELV S	60	mg/Nm ³					
Day	Status	Daily VLTA mg/Nm ³	Daily VLTA > ELV	VSTA > ELV	SSTA > calibr. range %	FLD outside meas. range	Subst. values in SSTA
01.01.21	Invalid	-	-	0	0.00	0	0
02.01.21	Invalid	-	-	0	0.00	0	0
03.01.21	Invalid	-	-	0	0.00	0	0
04.01.21	Invalid	-	-	0	0.00	0	0
05.01.21	Invalid	-	-	0	0.00	0	0
06.01.21	Invalid	-	-	0	0.00	0	0
07.01.21	Invalid	-	-	0	0.00	0	0
08.01.21	Invalid	-	-	0	0.00	0	0
09.01.21	Invalid	-	-	0	0.00	0	0
10.01.21	Invalid	-	-	0	0.00	0	0
11.01.21	Invalid	-	-	0	0.00	0	0
12.01.21	Invalid / P	-	-	0	0.00	0	4
13.01.21	Valid / P	0.03	0	0	0.00	0	1
14.01.21	Invalid / P	-	-	0	0.00	0	1
15.01.21	Valid / P	0.14	0	0	0.00	0	0
16.01.21	Valid / P	0.00	0	0	0.00	0	0
17.01.21	Valid / P	0.05	0	0	0.00	0	0
18.01.21	Valid / P	0.14	0	0	0.00	0	2
19.01.21	Valid / P	0.00	0	0	0.00	0	0
20.01.21	Valid / P	0.18	0	0	0.00	0	3
21.01.21	Valid / P	0.02	0	0	8.33	0	0
22.01.21	Valid / P	0.03	0	0	0.00	0	1
23.01.21	Invalid	-	-	0	0.00	0	0
24.01.21	Valid / P	0.32	0	0	0.00	0	2
25.01.21	Valid / P	0.06	0	0	0.00	0	1
26.01.21	Invalid / P	-	-	0	0.00	0	0
27.01.21	Valid / P	0.21	0	0	0.00	0	3
28.01.21	Valid / P	0.03	0	0	0.00	0	0
29.01.21	Valid / P	0.11	0	0	0.00	0	0
30.01.21	Valid / P	0.06	0	0	0.00	0	0
31.01.21	Valid / P	0.02	0	0	0.00	0	0
Average / Sum	Valid	0.07	0	0	0.27	0	18
Minimum		0.00			0.00		
Maximum		0.32			8.33		
Cumulative [%]			0.00	0.00			

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

HF							
Daily ELV	1	mg/Nm ³				STA reportable	696
Half-hourly ELV	4	mg/Nm ³				STA invalidated	2
ELV P	4	mg/Nm ³				STA periods	1488
ELV S	4	mg/Nm ³					
Day	Status	Daily VLTA mg/Nm ³	Daily VLTA > ELV	VSTA > ELV	SSTA > calibr. range %	FLD outside meas. range	Subst. values in SSTA
01.01.21	Invalid	-	-	0	0.00	0	0
02.01.21	Invalid	-	-	0	0.00	0	0
03.01.21	Invalid	-	-	0	0.00	0	0
04.01.21	Invalid	-	-	0	0.00	0	0
05.01.21	Invalid	-	-	0	0.00	0	0
06.01.21	Invalid	-	-	0	0.00	0	0
07.01.21	Invalid	-	-	0	0.00	0	0
08.01.21	Invalid	-	-	0	0.00	0	0
09.01.21	Invalid	-	-	0	0.00	0	0
10.01.21	Invalid	-	-	0	0.00	0	0
11.01.21	Invalid	-	-	0	0.00	0	0
12.01.21	Invalid / P	-	-	0	0.00	0	4
13.01.21	Valid / P	0.07	0	0	0.00	0	1
14.01.21	Invalid / P	-	-	0	0.00	0	1
15.01.21	Valid / P	0.03	0	0	0.00	0	0
16.01.21	Valid / P	0.02	0	0	0.00	0	0
17.01.21	Valid / P	0.01	0	0	0.00	0	0
18.01.21	Valid / P	0.01	0	0	0.00	0	2
19.01.21	Valid / P	0.03	0	0	0.00	0	0
20.01.21	Valid / P	0.02	0	0	0.00	0	3
21.01.21	Valid / P	0.00	0	0	6.25	0	0
22.01.21	Valid / P	0.02	0	0	0.00	0	1
23.01.21	Invalid	-	-	0	0.00	0	0
24.01.21	Valid / P	0.00	0	0	0.00	0	2
25.01.21	Valid / P	0.02	0	0	0.00	0	1
26.01.21	Invalid / P	-	-	0	0.00	0	0
27.01.21	Valid / P	0.03	0	0	0.00	0	3
28.01.21	Valid / P	0.04	0	0	0.00	0	0
29.01.21	Valid / P	0.03	0	0	0.00	0	0
30.01.21	Valid / P	0.05	0	0	0.00	0	0
31.01.21	Valid / P	0.04	0	0	0.00	0	0
Average / Sum	Valid	0.00	0	0	0.20	0	18
Minimum		0.00			0.00		
Maximum		0.07			6.25		
Cumulative [%]			0.00	0.00			

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

		CO						
Daily ELV		50	mg/Nm ³	ELV P	400	mg/Nm ³	STA reportable	696
Half-hourly ELV		100	mg/Nm ³	ELV S	400	mg/Nm ³	STA invalidated	2
10-minute ELV		150	mg/Nm ³				STA periods	1488
Day	Status	Daily VLTA mg/Nm ³	Daily VLTA > ELV	Half-hourly VSTA > ELV	Over 5% of 10-min VSTA > ELV in day	SSTA > calibr. range %	FLD > meas. range	Subst. values in SSTA
01.01.21	Invalid	-	-	0	0	0.00	0	0
02.01.21	Invalid	-	-	0	0	0.00	0	0
03.01.21	Invalid	-	-	0	0	0.00	0	0
04.01.21	Invalid	-	-	0	0	0.00	0	0
05.01.21	Invalid	-	-	0	0	0.00	0	0
06.01.21	Invalid	-	-	0	0	0.00	0	0
07.01.21	Invalid	-	-	0	0	0.00	0	0
08.01.21	Invalid	-	-	0	0	0.00	0	0
09.01.21	Invalid	-	-	0	0	0.00	0	0
10.01.21	Invalid	-	-	0	0	0.00	0	0
11.01.21	Invalid	-	-	0	0	0.00	0	0
12.01.21	Invalid / P	-	-	0	26	0.00	0	4
13.01.21	Valid / P	8.45	0	0	0	0.00	1	1
14.01.21	Invalid / P	-	-	0	0	0.00	0	1
15.01.21	Valid / P	12.32	0	0	0	0.00	0	0
16.01.21	Valid / P	2.37	0	0	0	0.00	0	0
17.01.21	Valid / P	25.30	0	1	0	0.00	1	0
18.01.21	Valid / P	18.02	0	0	0	0.00	0	2
19.01.21	Valid / P	3.49	0	0	0	0.00	0	0
20.01.21	Valid / P	11.38	0	0	0	0.00	0	3
21.01.21	Valid / P	0.00	0	0	0	8.33	0	0
22.01.21	Valid / P	2.30	0	0	0	0.00	0	1
23.01.21	Invalid	-	-	0	0	0.00	0	0
24.01.21	Valid / P	73.50	1	0	0	0.00	0	2
25.01.21	Valid / P	7.51	0	0	0	0.00	0	1
26.01.21	Invalid / P	-	-	1	37	0.00	2	0
27.01.21	Valid / P	10.91	0	0	19	0.00	1	3
28.01.21	Valid / P	2.28	0	0	0	0.00	0	0
29.01.21	Valid / P	0.82	0	0	0	0.00	0	0
30.01.21	Valid / P	2.10	0	0	0	0.00	0	0
31.01.21	Valid / P	0.99	0	0	0	0.00	0	0
Average / Sum	Valid	11.04	1	2	82	0.27	5	18
Minimum		0.00				0.00		
Maximum		73.50				8.33		
Cumulative [%]			6.25	0.29				

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

Time	Operating Times			Malfunction Times					
	Reportable Mode h	Status P h	Status S h	Abatement equipment h	FTIR h	DUST h	TOC h	O ₂ h	Flue gas flow h
01.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12.01.21	5.5	5.5	0.0	0.0	0.0	0.0	0.0	0.0	0.1
13.01.21	21.5	17.4	0.0	0.0	0.1	0.2	0.0	0.0	0.2
14.01.21	1.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
15.01.21	24.0	24.0	0.0	0.0	0.1	0.2	0.0	0.0	0.2
16.01.21	24.0	2.7	0.0	0.0	0.1	0.2	0.0	0.0	0.2
17.01.21	23.9	12.9	0.0	0.0	0.1	0.2	0.0	0.0	0.2
18.01.21	18.5	16.4	0.0	0.0	0.1	0.2	0.0	0.0	0.2
19.01.21	24.0	5.0	0.0	0.0	0.2	0.5	0.0	0.0	0.2
20.01.21	14.9	6.5	0.0	0.0	0.7	0.1	0.0	0.1	0.1
21.01.21	23.8	17.8	0.0	0.0	0.2	0.2	0.1	0.0	0.2
22.01.21	15.5	7.5	0.0	0.0	0.1	0.1	0.0	0.0	0.2
23.01.21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
24.01.21	6.5	6.5	0.0	0.0	0.0	0.1	0.0	0.0	0.0
25.01.21	23.0	14.2	0.0	0.0	0.1	0.2	0.0	0.0	0.2
26.01.21	3.9	3.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0
27.01.21	21.0	12.3	0.0	0.0	0.1	0.2	0.0	0.0	0.1
28.01.21	24.0	9.7	0.0	0.0	0.1	0.2	0.0	0.0	0.2
29.01.21	24.0	0.9	0.0	0.0	0.1	0.2	0.0	0.0	0.2
30.01.21	24.0	1.2	0.0	0.0	0.1	0.2	0.0	0.0	0.2
31.01.21	24.0	0.9	0.0	0.0	0.1	0.2	0.0	0.0	0.2
Average	11.2	5.4	0.0	0.0	0.1	0.1	0.0	0.0	0.1
Sum	346.9	0.0	0.0	0.0	1.7	3.6	0.6	0.1	3.0
Minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum	24.0	24.0	0.0	0.0	0.7	0.5	0.1	0.1	0.2
Cumulative time ¹		166.4	0.0	0.0	1.7	3.6	0.6		
Invalidated days ¹					0	0	0		
Rolling 12 month				67.4					

WtE MONTHLY EMISSION REPORT

Vilniaus kogeneracinė jėgainė



01.2021

Printing time: 01.02.2021 1:20 AM

Time	Process Values					
	Flue gas flow Nm ³ /s	Flue gas temperature °C	Flue gas pressure hPa	Combustion chamber temp °C	O ₂ %	H ₂ O %
01.01.21	-	-	-	-	-	-
02.01.21	-	-	-	-	-	-
03.01.21	-	-	-	-	-	-
04.01.21	-	-	-	-	-	-
05.01.21	-	-	-	-	-	-
06.01.21	-	-	-	-	-	-
07.01.21	-	-	-	-	-	-
08.01.21	-	-	-	-	-	-
09.01.21	-	-	-	-	-	-
10.01.21	-	-	-	-	-	-
11.01.21	-	-	-	-	-	-
12.01.21	7.78	37.35	1349.36	722.18	14.52	4.47
13.01.21	19.53	57.77	1007.08	997.38	9.74	17.92
14.01.21	5.53	49.40	1492.49	630.00	15.93	5.02
15.01.21	13.91	52.22	992.74	967.72	12.35	15.49
16.01.21	25.51	62.88	993.28	1016.49	10.48	26.63
17.01.21	23.40	62.49	997.67	1019.41	9.48	25.79
18.01.21	9.95	54.74	1053.37	919.55	14.32	16.88
19.01.21	29.95	63.50	996.56	1061.02	7.99	24.87
20.01.21	23.22	59.28	1025.14	1003.28	8.81	17.61
21.01.21	21.11	62.49	984.33	1038.13	11.77	15.86
22.01.21	37.78	61.13	1015.34	1042.43	7.02	20.67
23.01.21	-	-	-	-	-	-
24.01.21	9.06	41.37	1130.54	731.13	14.54	6.36
25.01.21	27.87	62.09	1001.14	1009.80	8.45	21.70
26.01.21	22.38	58.60	975.66	909.20	11.60	19.45
27.01.21	28.32	59.56	1052.10	972.53	8.43	18.67
28.01.21	33.93	64.08	984.06	1045.90	7.07	24.47
29.01.21	36.09	64.42	973.78	1046.95	7.09	25.05
30.01.21	35.89	64.13	973.69	1036.99	7.39	24.76
31.01.21	33.64	64.47	979.33	1046.62	7.48	25.03
Average	26.05	60.39	1008.84	1004.28	9.41	21.04
Minimum	5.53	37.35	973.69	630.00	7.02	4.47
Maximum	37.78	64.47	1492.49	1061.02	15.93	26.63

Statuses / flags:

Valid	Valid VSTA available for at least 6h of the day to form daily LTA or valid SSTA available for at least 10% of the month to form monthly LTA
Invalid	Valid VSTA available for less than 6h of the day to form daily LTA or valid SSTA available for less than 10% of the month to form monthly LTA
P	Boiler in start-up, shut-down or test
S	Malfunction of the boiler during normal operation
!	Daily VLTA exceeds the ELV
'	Uncertainty subtraction sets concentration value to zero
*	Disturbance time of AMS exceeds 2.5 h per day or invalidated days exceeds 10 days per year or time for P exceed 72h or cumulative time for S exceed 60h during 1 year
-	Invalid or boiler OFF or communication/server error

Abbreviations:

AMS	Automated Measuring System
ELV	Emission Limit Value
FLD	First Level Data
STA	Short-Term Average
SSTA	Standardized Short-Term Average
VSTA	Validated Short-Term Average
LTA	Long-Term Average
VLTA	Validated Long-Term Average

¹ Since 1st of January