

# DIOKSIŅŲ, FURANŲ IR DIOKSIŅŲ TIPO PCB MATAVIMŲ REZULTATAI

Atliktų matavimų tikslas – nustatyti į aplinką išmetamų dioksinų, furanų ir dioksinų tipo PCB (polichlorinti bifenilai) koncentraciją ir patvirtinti atitiktį leistinoms išmetimų normoms.

## Matavimų periodas

Nepertraukiamas dūmų mėginio ėmimas buvo vykdomas nuo 2024 m. lapkričio mėn. 22 d. 09:33 val. iki 2024 m. gruodžio mėn. 19 d. 11:06 val.

## Dioksinų, furanų ir dioksinų tipo PCB koncentracija

Išmetamų dioksinų ir furanų bei dioksinų tipo PCB koncentracijos analizės rezultatai pateikiami 1 paveiksle.

## Rezultatų suvestinė

Galutiniai išmetamų dioksinų ir furanų bei dioksinų tipo PCB koncentracijos analizės rezultatai yra pateikiami ir palyginami su leistinomis ribinėmis normomis 1 lentelėje.

**1 lentelė.** Dioksinų, furanų ir dioksinų tipo PCB analizės rezultatų palyginimas su leistinomis ribinėmis normomis.

Parametras	Vienetai	Ribinės vertės	Rezultatai
PCDD/F ir dioksinų tipo PCB	ng / Nm <sup>3</sup>	0,08	0,0013



### Analytical Results

Sub-Matrix: EMISSIONS

Client sample ID

2024\_12\_KKJ\_DX1  
00\_SMT-202311\_0  
01

---

---

Laboratory sample ID  
Client sampling date / time

PR24G0943001  
[28-Dec-2024]

---

---

Parameter	Method	LOR	Unit	Result	MU	Result	MU	Result	MU
<b>PCDDs and PCDFs (Dioxins and Furans)</b>									
2378-TCDD	A-DFHMS02	-	ng/m <sup>3</sup>	<0.00004	---	---	---	---	---
12378-PeCDD	A-DFHMS02	-	ng/m <sup>3</sup>	<0.000066	---	---	---	---	---
123478-HxCDD	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.00056</b>	---	---	---	---	---
123678-HxCDD	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.0011</b>	---	---	---	---	---
123789-HxCDD	A-DFHMS02	-	ng/m <sup>3</sup>	<0.000073	---	---	---	---	---
1234678-HpCDD	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.0004</b>	---	---	---	---	---
OCDD	A-DFHMS02	-	ng/m <sup>3</sup>	<0.00015	---	---	---	---	---
2378-TCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.0019</b>	---	---	---	---	---
12378-PeCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<0.000077	---	---	---	---	---
23478-PeCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.00073</b>	---	---	---	---	---
123478-HxCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.00097</b>	---	---	---	---	---
123678-HxCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.0009</b>	---	---	---	---	---
123789-HxCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<0.000053	---	---	---	---	---
234678-HxCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.0014</b>	---	---	---	---	---
1234678-HpCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.0012</b>	---	---	---	---	---
1234789-HpCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<0.00009	---	---	---	---	---
OCDF	A-DFHMS02	-	ng/m <sup>3</sup>	<0.00016	---	---	---	---	---
TEQ-Lowerbound	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.00095</b>	---	---	---	---	---
TEQ-Upperbound	A-DFHMS02	-	ng/m <sup>3</sup>	<b>0.0011</b>	---	---	---	---	---
<b>PCB dioxin-like HRMS</b>									
PCB 77	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.0043	---	---	---	---	---
PCB 81	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.00018	---	---	---	---	---
PCB 105	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.00057	---	---	---	---	---
PCB 114	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.00012	---	---	---	---	---
PCB 118	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.02	---	---	---	---	---
PCB 123	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.00012	---	---	---	---	---
PCB 126	A-PCBHMS03	-	ng/m <sup>3</sup>	<b>0.00190</b>	± 30.0%	---	---	---	---
PCB 156	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.0035	---	---	---	---	---
PCB 157	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.00024	---	---	---	---	---
PCB 167	A-PCBHMS03	-	ng/m <sup>3</sup>	<b>0.00290</b>	± 30.0%	---	---	---	---
PCB 169	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.00041	---	---	---	---	---
PCB 170	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.0082	---	---	---	---	---
PCB 180	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.013	---	---	---	---	---
PCB 189	A-PCBHMS03	-	ng/m <sup>3</sup>	<0.0002	---	---	---	---	---
TEQ (dl-PCB) - lower	A-PCBHMS03	-	ng/m <sup>3</sup>	<b>0.00019</b>	---	---	---	---	---
TEQ (dl-PCB) - upper	A-PCBHMS03	-	ng/m <sup>3</sup>	<b>0.0002</b>	---	---	---	---	---
<b>PCB indicators HRMS</b>									
PCB 28	A-PCBHMS05	-	ng/m <sup>3</sup>	<0.057	---	---	---	---	---
PCB 52	A-PCBHMS05	-	ng/m <sup>3</sup>	<0.029	---	---	---	---	---
PCB 101	A-PCBHMS05	-	ng/m <sup>3</sup>	<0.051	---	---	---	---	---
PCB 118	A-PCBHMS05	-	ng/m <sup>3</sup>	<0.02	---	---	---	---	---
PCB 138	A-PCBHMS05	-	ng/m <sup>3</sup>	<0.048	---	---	---	---	---
PCB 153	A-PCBHMS05	-	ng/m <sup>3</sup>	<0.062	---	---	---	---	---
PCB 180	A-PCBHMS05	-	ng/m <sup>3</sup>	<0.013	---	---	---	---	---
Total Polychlorinated biphenyls - 7 congeners - lower	A-PCBHMS05	-	ng/m <sup>3</sup>	<b>0</b>	---	---	---	---	---
Total Polychlorinated biphenyls - 7 congeners - upper	A-PCBHMS05	-	ng/m <sup>3</sup>	<b>0.28</b>	---	---	---	---	---

When sampling date is not provided by the client, the laboratory determines it for procedural reasons, then it is equal to the date of receipt of the sample to the laboratory and is displayed in brackets. Measurement uncertainty is expressed as expanded measurement uncertainty with coverage factor k = 2, representing 95% confidence level.

Key: LOR = Limit of reporting, MU = Measurement Uncertainty. The MU does not include sampling uncertainty.

## 1 pav. Dioksinų, furanų ir dioksinų tipo PCB analizės rezultatai